

KABALE AREA

Report Date: 22nd September 2015

Table: Water Quality for Selected Zones in Kabale during the week of 18th September 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Makanga	Kitumb a zone	Mwendo zone	Kijugut a zone	Kabale Central Town	
CODE		KBL08	KBL09	KBL10	KBL11	KBL12	KBL13	KBL14	
pH	6.5	6.6	6.6	6.6	6.6	6.6	6.6	5.5 – 8.5
Turbidity	NTU	3.7	0.7	0.8	0.5	0.6	0.5	0.5	≤5.00
Colour	PtCo.	26	11	11	9	11	7	9	≤15
Residue Aluminium	Mg/l	N/A	0.15	NR	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	1.23	0.45	0.32	0.35	0.20	0.23	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	-	0	0	0	0	0	0	0