

Report date: 6th July 2015

Table: Average water quality for Kampala during the period of 29th June - 3rd July 2015

Parameter	National Standard for portable water	Monitoring Points													
		Kisenyi	Masanafu	Namugoona	Nansana	Muyenga	Makerere	Nakulabye	Bukoto	Kabalagala	Kitintale	Nakasero	Lugala	Bwaise	Wakiso
pH	6.5-8.5	7.3	7.1	7.1	7.1	7.1	7.1	7.1	7.2	7.1	7.1	7.2	7.0	7.1	6.3
Electrical Conductivity (μ S/cm)	1500	137	141	140	140	144	139	140	140	140	143	145	142	138	150
Turbidity (NTU)	5	0.98	0.56	0.42	0.61	0.26	0.5	0.68	0.61	0.63	0.58	0.00	0.43	0.53	0
Colour (PtCo)	15	11	8	9	10	8	11	12	7	12	13	6	7	9	2
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.20	0.20	0.30	0.45	0.40	0.40	0.25	0.45	0.25	0.25	0.20	0.30	0.30