

Report date: 17th October 2016

Table: Average water quality for Kampala during the period of 10th- 16th October 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Naguru	Kololo	Ntinda	Mukono	Seeta	Kamwokya	Mulago	Kyebando	Kanyanya	Nansana	Namungoona	Makindye	Buziga	Munyonyo
pH	6.5-8.5	7.4	7.3	7.4	7.4	7.4	7.2	7.2	7.4	7.2	7.4	7.4	7.1	7.2	7.2
Electrical Conductivity (µs/cm)	≤1500	122	135	125	156	159	148	143	126	137	151	154	140	147	145
Turbidity (NTU)	≤5.00	0.81	0.55	0.79	0.68	0.69	0.69	0.65	0.56	0.68	0.64	0.68	0.79	0.54	0.60
Colour (PtCo)	≤15	7	2	7	5	5	6	4	6	5	5	5	6	4	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.40	0.35	0.25	0.25	0.35	0.35	0.25	0.40	0.35	0.25	0.35	0.40	0.35