

Report date: 24th October 2016

Table: Average water quality for Kampala during the period of 17th- 23rd October 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Ntinda	Matuga	Masanafu	Lunguja	Mutundwe	Kansanga	Bukasa	Muyenga	Nsambya	Kibuli	Namuwongo	Nakasero	Bugolobi	Luzira
pH	6.5-8.5	7.3	7.4	7.4	7.4	7.4	7.2	7.2	7.5	7.2	7.3	7.3	7.4	7.3	7.3
Electrical Conductivity (µs/cm)	≤1500	153	154	141	156	166	135	136	130	132	130	130	127	127	135
Turbidity (NTU)	≤5.00	0.78	0.62	0.79	0.68	0.69	0.58	0.71	0.82	0.68	0.55	0.68	0.79	0.54	0.60
Colour (PtCo)	≤15	6	4	6	6	4	4	7	7	6	4	4	5	6	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.25	0.25	0.30	0.30	0.30	0.35	0.45	0.35	0.35	0.30	0.35	0.30	0.25