

Report date: 31st October 2016

Table: Average water quality for Kampala during the period of 24th- 30th October 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Buziga	Makindye	Lubowa	Sseguku	Katwe	Kisenyi	Makerere	Wandegeya	Bwaise	Mutungo	Bugolobi	Kitintale	Bakuli	Kibuye
pH	6.5-8.5	7.4	7.4	7.3	7.3	7.4	7.4	7.3	7.4	7.4	7.2	7.3	7.2	7.2	7.2
Electrical Conductivity (µs/cm)	≤1500	127	128	130	130	127	126	129	126	120	127	127	127	121	127
Turbidity (NTU)	≤5.00	0.85	0.78	0.82	0.79	0.82	0.78	0.75	0.82	0.66	0.84	0.77	0.76	0.56	0.72
Colour (PtCo)	≤15	7	6	6	5	7	6	6	7	5	7	6	6	5	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.35	0.30	0.25	0.25	0.30	0.30	0.30	0.35	0.25	0.35	0.30	0.30	0.25	0.25