

Report date: 19th September 2016

Table: Average water quality for Kampala during the period of 12th - 18th September 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Namuwongo	Muyenga	Nsambya	Rubaga	Kisugu	Namirembe	Ggaba	Mukono	Seeta	Kalerwe	Makerere	Bulenga	Buloba	Bwaise
pH	6.5-8.5	7.	7.4	7.3	7.4	7.4	7.3	7.4	7.4	7.3	7.5	7.2	7.1	7.2	7.2
Electrical Conductivity (µs/cm)	≤1500	128	127	127	135	127	133	127	124	129	124	125	132	126	126
Turbidity (NTU)	≤5.00	0.52	0.72	0.66	0.74	0.38	0.73	0.76	0.93	0.86	0.67	0.68	0.88	0.88	0.69
Colour (PtCo)	≤15	5	6	5	5	3	5	9	8	7	9	9	9	8	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.35	0.35	0.35	0.35	0.25	0.40	0.25	0.30	0.35	0.35	0.35	0.25	0.35