

Report date: 26th September 2016

Table: Average water quality for Kampala during the period of 19th - 25th September 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Kabanyoro	Bunamwaya	Nyanama	Kibuye	Mpererwe	Mutundwe	Kyebando	Gayaza	Nakasero	Butabika	Bugolobi	Luzira	Mbuya	Mutungo
pH	6.5-8.5	7.3	7.4	7.4	7.4	7.2	7.2	7.2	7.3	7.2	7.1	7.2	7.0	7.1	7.2
Electrical Conductivity (µs/cm)	≤1500	141	134	131	126	124	125	123	159	126	130	132	134	134	135
Turbidity (NTU)	≤5.00	0.79	0.54	0.48	0.42	0.53	0.45	0.69	0.59	0.37	0.52	0.69	0.59	0.68	0.66
Colour (PtCo)	≤15	8	5	6	5	5	5	6	6	3	6	8	6	7	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.25	0.30	0.30	0.35	0.30	0.30	0.35	0.30	0.35	0.35	0.30	0.35	0.35	0.30