

Report date: 3rd October 2016

Table: Average water quality for Kampala during the period of 26th September - 2nd October 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Makerere	Luzira	Mutungo	Kibuli	Namasuba	Makindye	Mbuya	Rubaga	Muyenga	Nakawa	Nambole	Kirinya	kitintale	Bukasa
pH	6.5-8.5	7.5	7.4	7.3	7.0	7.5	7.5	7.4	7.4	7.5	7.3	7.4	7.3	7.3	7.4
Electrical Conductivity (µs/cm)	≤1500	128	126	125	126	121	126	129	127	126	124	124	127	126	124
Turbidity (NTU)	≤5.00	0.51	0.59	0.74	0.61	0.68	0.65	0.81	0.84	0.59	0.55	0.68	0.75	0.68	0.74
Colour (PtCo)	≤15	5	4	7	5	6	6	9	9	7	5	7	8	7	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.35	0.30	0.35	0.35	0.30	0.30	0.30	0.30	0.45	0.30	0.30	0.35	0.25	0.30