

Report date: 15th February 2016

Table: Average water quality for Kampala during the period of 08th - 14th February 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Bwaise	Kawempe	Kireka	Nakawa	Bulenga	Rubaga	Nakasero	Kisenyi	Busabala R.d	Buziga	Makindye	Salaama	Mukono	Namawojolo
pH	6.5-8.5	7.2	7.1	7.3	7.1	7.4	7.3	7.3	7.4	7.4	7.3	7.3	7.3	7.2	7.3
Electrical Conductivity (µs/cm)	≤1500	134	134	135	134	130	131	133	132	130	128	130	130	134	134
Turbidity (NTU)	≤5.00	0.66	0.90	0.78	0.81	0.98	0.71	0.39	0.42	0.57	0.64	0.91	0.71	0.78	0.72
Colour (PtCo)	≤15	8	9	8	9	10	8	2	5	2	4	9	4	8	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.25	0.35	0.30	0.30	0.25	0.25	0.40	0.30	0.25	0.30	0.35	0.35	0.25	0.25