

**Report date:** 11<sup>th</sup> April 2016

**Table:** Average water quality for Kampala during the period of 04<sup>th</sup> - 10<sup>th</sup> April 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Bulange	Buloba	Busega	Rubaga	Luzira	Butabika	Kiswa	Lugogo	Bugolobi	Nakasero	Kololo	Makerere	Mulago	Wandegeya
pH	6.5-8.5	7.4	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.3	7.2	7.2
Electrical Conductivity (µs/cm)	≤1500	160	157	161	158	162	160	163	164	130	153	166	155	167	159
Turbidity (NTU)	≤5.00	0.74	0.72	0.78	0.85	0.92	0.76	0.49	0.41	0.47	0.42	0.51	0.56	0.62	0.76
Colour (PtCo)	≤15	8	7	8	9	10	8	6	5	5	3	4	5	6	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.25	0.25	0.30	0.30	0.25	0.25	0.35	0.30	0.30	0.30	0.35	0.35	0.25	0.25