

Report date: 18th April 2016

Table: Average water quality for Kampala during the period of 11th - 17th April 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Kibuli	Kisugu	Nsambya	Namuwongo	Naguru	Naalya	Najjera	Kyambogo	Ntinda	Kiwatule	Kalinabiri	Kamwokya	Rubaga	Busoga
pH	6.5-8.5	7.0	7.1	7.2	7.1	7.0	7.1	7.1	7.0	7.0	7.1	7.0	7.1	7.2	7.3
Electrical Conductivity (µs/cm)	≤1500	139	139	139	133	135	133	131	136	132	134	136	136	153	157
Turbidity (NTU)	≤5.00	0.66	0.88	0.98	0.88	0.97	0.76	0.62	0.77	0.55	0.68	0.78	0.85	0.97	0.91
Colour (PtCo)	≤15	7	7	6	7	8	7	7	8	5	7	7	6	8	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.25	0.35	0.35	0.30	0.30	0.30	0.30	0.35	0.25	0.35	0.30	0.35	0.25