

Report date: 22nd February 2016

Table: Average water quality for Kampala during the period of 15th - 21st February 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Bweyogerere	Kinawataka	Luzira	Naguru	Ntinda	Naalya	Mutungo	Najjera	Nakasero	Mbuya	Kungu	Kisaasi	Namboole	Kitintale
pH	6.5-8.5	7.1	7.2	7.3	7.1	7.3	7.3	7.2	7.3	7.3	7.1	7.3	7.3	7.2	7.3
Electrical Conductivity (µs/cm)	≤1500	130	130	130	126	133	133	128	127	127	129	129	130	130	131
Turbidity (NTU)	≤5.00	0.88	0.84	0.68	0.98	0.93	0.79	0.69	0.67	0.47	0.62	0.79	0.70	0.73	0.76
Colour (PtCo)	≤15	9	8	7	10	9	8	7	6	2	6	8	6	7	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.25	0.25	0.35	0.40	0.30	0.35	0.35	0.30	0.35	0.40	0.35	0.30	0.35	0.30