

Report date: 25th April 2016

Table: Average water quality for Kampala during the period of 18th - 24th April 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Bukasa	Kirinya	Kitintale	Nambole	Kinawataka	Bweyogerere	Mbuya	Rubaga	Muyenga	Nakawa	Makerere	Luzira	Mutungo	Kibuli
pH	6.5-8.5	7.1	7.2	7.1	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.1	7.1	7.2	7.1
Electrical Conductivity (µs/cm)	≤1500	178	177	175	176	171	177	174	172	170	173	167	174	172	174
Turbidity (NTU)	≤5.00	0.61	0.59	0.84	0.61	0.78	0.67	0.81	0.83	0.59	0.53	0.68	0.75	0.68	0.74
Colour (PtCo)	≤15	5	4	7	5	6	6	9	9	7	5	7	8	7	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.35	0.30	0.35	0.30	0.30	0.30	0.30	0.30	0.45	0.30	0.30	0.35	0.25	0.30