

Report date: 29th February 2016

Table: Average water quality for Kampala during the period of 22nd - 28st February 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Makerere	Kyebando	Kasubi	Mulago	Naguru	Nankulabye	Lubowa	Namasuba	Kololo	Nakawa	Banda	Kyaliwajjala	Mutungo	Namugongo
pH	6.5-8.5	7.3	7.3	7.4	7.2	7.4	7.5	7.4	7.4	7.5	7.5	7.4	7.5	7.4	7.5
Electrical Conductivity (µs/cm)	≤1500	131	132	131	133	128	133	134	131	132	132	132	131	132	133
Turbidity (NTU)	≤5.00	0.66	0.88	0.98	0.88	0.97	0.76	0.62	0.77	0.55	0.68	0.78	0.85	0.97	0.91
Colour (PtCo)	≤15	7	8	9	9	9	9	8	9	5	8	7	9	10	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.25	0.30	0.30	0.30	0.30	0.30	0.30	0.35	0.25	0.30	0.30	0.35	0.25