

Report date: 07th March 2016

Table: Average water quality for Kampala during the period of 29th Feb. 2016 - 06th March 2016

Parameter						Monitoring points									
	National Standard For Portable Water	Mulago	Kamwokya	Kiwatule	Kyambogo	Kulambiro	Namungoona	Nansana	Rubaga	Muyenga	Nakasero	Makerere	Luzira	Mutungo	Kibuli
pH	6.5-8.5	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.3	7.4	7.4	7.5
Electrical Conductivity (µs/cm)	≤1500	134	135	135	137	135	135	134	136	130	133	133	134	134	133
Turbidity (NTU)	≤5.00	0.71	0.69	0.82	0.51	0.84	0.65	0.91	0.89	0.49	0.53	0.78	0.85	0.68	0.79
Colour (PtCo)	≤15	6	5	9	4	9	6	10	9	3	4	8	7	5	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.30	0.40	0.30	0.40	0.30	0.25	0.30	0.45	0.30	0.25	0.35	0.25	0.25