

Report date: 24th August 2015

Table: Average water quality for Kampala during the period of 17th - 21st August 2015

Parameter	Standard for portable water	Monitoring Points													
		Old Kampala	Kyebando	Makerere	Bwaise	Nansana	Nakasero	Bugolobi	Muyenga	Nsambya	Kibuli	Kyambogo	Namugongo	Mukono	Wakiso
pH	6.5-8.5	7.5	8.2	8.2	8.2	7.0	8.2	7.8	7.1	7.2	7.3	7.9	7.5	7.6	7.1
Electrical Conductivity (µs/cm)	1500	131	124	121	124	135	133	132	127	127	127	130	135	128	146
Turbidity (NTU)	5	1.69	1.57	1.39	1.38	1.36	1.44	1.64	1.04	1.13	1.45	1.57	1.02	1.41	0.34
Colour (PtCo)	15	12	10	9	11	10	5	7	6	6	8	9	9	10	0
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.30	0.20	0.35	0.20	0.20	0.30	0.25	0.45	0.45	0.20	0.25	0.20	0.25	0.20

