

**Report date:** 7<sup>th</sup> September 2015

**Table:** Average water quality for Kampala during the period of 31<sup>st</sup> August - 4<sup>th</sup> September 2015

Parameter	Standard for portable water	Monitoring Points													
		Kololo	Nakawa	Lugala	Nansana	Mutungo	Namungoona	Kitante	Kireka	Mukono	Muyenga	Kisaasi	Kiwatule	Ntinda	Wakiso
pH	6.5-8.5	7.7	7.7	7.5	7.5	7.5	7.5	7.7	7.6	7.2	7.3	7.7	7.8	7.7	7.0
Electrical Conductivity ( $\mu\text{s}/\text{cm}$ )	1500	131	129	127	131	132	128	127	133	138	135	126	126	125	159
Turbidity (NTU)	5	0.42	0.67	0.91	0.94	0.49	0.75	0.76	0.78	0.66	0.31	0.79	0.64	0.68	0
Colour (PtCo)	15	7	8	10	10	7	9	8	10	9	4	11	12	12	0
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.35	0.25	0.20	0.35	0.30	0.45	0.20	0.20	0.45	0.20	0.20	0.35	0.40

