

**Report date:** 10<sup>th</sup> August 2015

**Table:** Average water quality for Kampala during the period of 3<sup>rd</sup> - 7<sup>th</sup> August 2015

Parameter	Standard for portable water	Monitoring Points													
		Kololo	Masanafu	Namugooona	Nansana	Muyenga	Makerere	Bwaise	Seeta	Munyonyo	Komamboga	Kyebando	Lugala	Kabalagala	Wakiso
pH	6.5-8.5	7.0	7.0	7.3	7.0	7.1	7.0	7.0	7.1	7.0	7.0	7.1	7.0	7.1	6.5
Electrical Conductivity ( $\mu\text{S}/\text{cm}$ )	1500	131	132	133	131	144	134	134	132	136	131	131	133	132	150
Turbidity (NTU)	5	0.53	0.64	0.99	0.68	0.26	0.5	0.68	0.61	0.47	0.87	0.83	0.87	0.53	0
Colour (PtCo)	15	7	11	12	10	8	10	12	10	7	8	8	10	7	2
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.20	0.20	0.25	0.45	0.40	0.25	0.30	0.45	0.25	0.25	0.20	0.45	0.35

**Report date:** 18<sup>th</sup> May 2015

**Table:** Average water quality for Kampala during the period of 11<sup>th</sup> – 15<sup>th</sup> May 2015

Parameter	National Standard for portable water	Monitoring Points													
		Ntinda	City Centre	Mengo	Namugoona	Kalerwe	Kololo	Kitintale	Naguru	Kamwokya	Bukoto	Namanve	Seeta	Mutundwe	Wakiso
pH	6.5-8.5	7.1	7.0	7.0	7.1	7.2	7.0	7.2	7.1	7.1	7.3	7.1	7.2	7.0	7.0
Electrical Conductivity ( $\mu\text{s/cm}$ )	1500	137	140	136	134	138	139	138	136	137	136	138	139	137	157
Turbidity (NTU)	5	0.45	0.37	0.73	0	0.39	0.26	0.52	0.67	0.95	0.98	0.34	0.72	0.58	0
Colour (PtCo)	15	8	3	11	0	8	3	2	8	10	10	9	6	10	0
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.40	0.30	0.30	0.30	0.20	0.25	0.35	0.40	0.40	0.25	0.25	0.28	0.20

**Report date:** 25<sup>th</sup> May 2015

**Table:** Average water quality for Kampala during the period of 18<sup>th</sup> – 22<sup>th</sup> May 2015

Parameter	National Standard for portable water	Monitoring Points													
		Lugogo	Buloba	Busega	Nabingo	Wandegeya	Bwaise	Kawanda	Matugga	Luzira	Namuwongo	Kabalagala	Nsambya	Busabala	Zana
pH	6.5-8.5	7.0	7.29	7.11	7.23	7.23	7.2	7.1	7.21	7.0	7.1	7.1	7.2	7.04	7.01
Electrical Conductivity ( $\mu\text{S/cm}$ )	1500	131	138	136	137	133	134	133	132	137	134	134	133	133	133
Turbidity (NTU)	5	0.62	0.70	0.35	0	0	0.28	0	0	0	0.08	0.51	0.48	0.32	0.57
Colour (PtCo)	15	8	5	4	0	0	0	0	0	0	10	5	7	9	11
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.30	0.30	0.25	0.20	0.45	0.30	0.25	0.25	0.30	0.30	0.50	0.40	0.25	0.20