

**Report date:** 31<sup>st</sup> August 2015

**Table:** Average water quality for Kampala during the period of 24<sup>th</sup> - 28<sup>th</sup> August 2015

Parameter	Standard for portable water	Monitoring Points													
		City Centre	Naguru	Lungujja	Rubaga	Nabingo	Bunamwaya	Kawempe	Matugga	Naalya	Namuwongo	Lubowa	Kyebando	Najjera	Namasuba
pH	6.5-8.5	7.3	7.3	7.2	7.4	7.4	7.3	7.3	7.3	7.2	7.2	7.3	7.0	7.2	7.3
Electrical Conductivity (µs/cm)	1500	120	124	125	123	125	128	120	121	122	127	127	128	125	127
Turbidity (NTU)	5	0.51	0.95	0.82	0.84	0.76	0.65	0.52	0.88	0.69	0.98	0.74	0.99	0.67	0.48
Colour (PtCo)	15	7	10	11	9	12	8	8	11	9	8	10	12	8	7
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.35	0.20	0.25	0.30	0.20	0.30	0.25	0.20	0.30	0.30	0.25	0.20	0.25	0.45