

Report date: 28th December 2015

Table: Average water quality for Kampala during the period of 21st - 25th December 2015

Parameter	Standard for portable water	Monitoring Points													
		City Centre	Kibuli	Rubaga	Matugga	Nansana	Kabalagala	Wandegeya	Naguru	Gaba	Ntinda	Muyenga	Kisenyi	Mukono	Wakiso
	6.5-8.5	7.4	7.3	7.0	7.1	7.0	7.3	7.4	7.0	7.3	7.4	7.1	7.4	7.4	6.7
Electrical Conductivity ($\mu\text{S/cm}$)	1500	149	145	153	156	151	146	145	149	146	148	157	148	158	166
Turbidity (NTU)	5	0.73	0.86	0.67	0.69	0.82	0.63	0.75	0.86	0.59	0.91	0.86	0.65	0.89	0.43
Colour (PtCo)	15	6	8	7	9	8	6	8	10	6	11	8	2	9	3
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.20	0.25	0.20	0.20	0.30	0.25	0.40	0.30	0.35	0.40	0.20	0.25	0.20

