

**Report date:** 01<sup>st</sup> February 2016

**Table:** Average water quality for Kampala during the period of 25<sup>th</sup> - 31<sup>st</sup> January 2016

Parameter						Monitoring points									
	National Standard For portable water	Kisaasi	Kyebando	Ntinda	Buziga	Rubaga	Busega	Kasimbiri	Nakasero	Bugolobi	Kololo	Naguru	Najjanankumbi	Busega	Kyambogo
pH	6.5-8.5	7.7	7.7	7.8	7.2	7.3	7.1	6.6	7.4	7.4	7.2	7.7	7.2	7.2	7.6
Electrical Conductivity (µs/cm)	≤1500	134	137	135	135	136	137	169	137	138	138	135	136	137	138
Turbidity (NTU)	≤5.00	0.92	0.78	0.82	0.71	0.87	0.79	0.28	0.42	0.41	0.94	0.96	0.98	0.68	0.79
Colour (PtCo)	≤15	7	6	8	7	9	8	0	4	2	9	10	8	6	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.30	0.30	0.35	0.25	0.25	0.40	0.25	0.30	0.25	0.40	0.30	0.30	0.25