

**Report date:** 04<sup>th</sup> January 2016

**Table:** Average water quality for Kampala during the period of 28<sup>th</sup> December 2015 - 03<sup>rd</sup> January 2016

Parameter						Monitoring points									
	National Standard For portable water	Luzira	Mutungo	Kirinya	Bwaise	Kawanda	Kamwokya	Naguru	Mulago	Nakasero	Kololo	Kiswa	Kawala	Lugogo	Mbuya
pH	6.5-8.5	7.4	7.4	7.4	7.6	7.6	7.5	7.7	7.6	7.4	7.3	7.3	7.6	7.5	7.4
Electrical Conductivity (µs/cm)	≤1500	146	145	146	148	150	146	145	148	146	144	145	150	145	147
Turbidity (NTU)	≤5.00	0.96	0.66	0.84	0.92	0.98	0.87	0.93	0.82	0.74	0.87	0.85	0.88	0.82	0.78
Colour (PtCo)	≤15	4	7	9	10	7	8	10	8	5	6	8	9	6	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.35	0.25	0.30	0.30	0.25	0.35	0.35	0.35	0.30	0.30	0.30	0.25	0.35	0.30