

Report date: 20th July 2015

Table: Average water quality for Kampala during the period of 13th - 19th July 2015

| Parameter | | | | | | Monitoring points | | | | | | | | | |
|------------------------------------|--|-------|--------|----------|---------|-------------------|---------|---------|--------|----------|-----------|----------|--------|----------|---------|
| | National Standard For portable water | Seeta | Lugala | Makerere | Nansana | UMI | Kisaasi | Muyenga | Naguru | Mpererwe | Kitintale | Kyebando | Mukono | Kyebando | Kalerwe |
| pH | 6.6-8.5 | 7.1 | 6.9 | 7.0 | 7.0 | 7.0 | 7.1 | 7.1 | 7.1 | 7.0 | 7.0 | 7.2 | 7.3 | 7.1 | 6.9 |
| Electrical Conductivity (µs/cm) | ≤1500 | 132 | 142 | 131 | 130 | 134 | 136 | 132 | 138 | 130 | 141 | 130 | 131 | 130 | 129 |
| Turbidity (NTU) | ≤5.00 | 0.68 | 0.53 | 0.69 | 0.76 | 0.62 | 0.85 | 0.72 | 0.77 | 0.68 | 0.58 | 0.82 | 0.82 | 0.83 | 0.53 |
| Colour (PtCo) | ≤15 | 9 | 5 | 8 | 6 | 5 | 11 | 8 | 9 | 8 | 6 | 9 | 11 | 10 | 10 |
| Escherichia coliforms (CFU/100m/L) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Faecal coliforms (CFU/100m/L) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Residual Chlorine (mg/L) | 0.2-0.5 | 0.25 | 0.25 | 0.30 | 0.30 | 0.35 | 0.30 | 0.40 | 0.40 | 0.25 | 0.30 | 0.30 | 0.25 | 0.35 | 0.35 |