

Report date: 02nd November 2015

Table: Average water quality for Kampala during the period of 26th Oct- 01st November 2015

Parameter						Monitoring points									
	National Standard For portable water	Banda	Mutungo	Bukasa	Buziga	Makindye	Lubiri	Mengo	Ndeeba	Kyengera	Busabala	Kinawataka	Makerere	Nakulabye	Kisenyi
pH	6.6-8.5	7.3	7.3	7.4	7.3	7.4	7.4	7.5	7.4	7.5	7.5	7.5	7.5	7.4	7.4
Electrical Conductivity (µs/cm)	≤1500	147	143	127	137	138	137	140	140	143	138	125	143	136	125
Turbidity (NTU)	≤5.00	0.87	0.69	0.89	0.84	0.74	0.91	0.96	0.92	0.68	0.90	0.61	0.94	0.85	0.97
Colour (PtCo)	≤15	7	5	9	8	7	9	5	8	5	8	7	9	10	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.25	0.30	0.40	0.30	0.35	0.35	0.35	0.30	0.25	0.30	0.25	0.25	0.30