

Report date: 30th November 2015

Table: Average water quality for Kampala during the period of 23rd - 29th November 2015

| Parameter | Standard for portable water | Monitoring Points | | | | | | | | | | | | | |
|--|-----------------------------|-------------------|--------|----------|--------|----------|----------|--------|--------|-------|---------|----------|-----------|---------|--------|
| | | Nansana | Kololo | Makindye | Ntinda | Munyonyo | Namwongo | Naalya | Kireka | Mbuya | Muyenga | Bugolobi | Namugongo | Mutungo | Wakiso |
| pH | 6.5-8.5 | 7.6 | 7.9 | 7.1 | 7.5 | 7.2 | 7.0 | 7.5 | 7.6 | 7.9 | 7.0 | 7.5 | 7.3 | 7.6 | 7.0 |
| Electrical Conductivity ($\mu\text{s/cm}$) | 1500 | 160 | 157 | 143 | 151 | 145 | 170 | 149 | 155 | 162 | 166 | 165 | 142 | 164 | 123 |
| Turbidity (NTU) | 5 | 0.82 | 0.43 | 0.88 | 0.99 | 0.91 | 0.72 | 0.87 | 0.84 | 0.96 | 0.72 | 0.94 | 0.41 | 0.81 | 0.58 |
| Colour (PtCo) | 15 | 9 | 5 | 11 | 9 | 8 | 7 | 10 | 9 | 8 | 8 | 9 | 7 | 10 | 2 |
| Esherichia coliform (cfu/100 mL) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Feacal coliform (cfu/100 mL) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Residual Chlorine (mg/l) | 0.20 – 0.50 | 0.25 | 0.40 | 0.20 | 0.20 | 0.45 | 0.20 | 0.35 | 0.30 | 0.40 | 0.45 | 0.35 | 0.35 | 0.45 | 0.20 |