

**Report date:** 9th November 2015

**Table:** Average water quality for Kampala during the period of 2<sup>nd</sup> - 6<sup>th</sup> November 2015

Parameter	Standard for portable water	Monitoring Points													
		Rubaga	Lungujja	Bukasa	Gaba	Muyenga	Nsambya	Katwe	Naguru	Mbuya	Bugolobi	Namugongo	Ntinda	Kiwatule	Kyanja
pH	6.5-8.5	7.6	7.5	7.3	7.5	7.1	7.5	7.5	7.0	7.8	7.4	7.5	7.4	7.4	7.5
Electrical Conductivity ( $\mu\text{s/cm}$ )	1500	145	144	143	140	148	142	142	132	139	140	146	125	129	133
Turbidity (NTU)	5	0.81	0.83	0.40	0.37	0.39	0.73	0.88	0.77	0.8	0.68	0.84	0.86	0.92	0.98
Colour (PtCo)	15	9	11	6	1	4	8	10	8	9	8	10	11	12	12
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.30	0.20	0.35	0.40	0.40	0.30	0.25	0.30	0.25	0.30	0.25	0.25	0.20	0.20