

**Report date:** 19th October 2015

**Table:** Average water quality for Kampala during the period of 12<sup>th</sup> - 16<sup>th</sup> October 2015

Parameter	Standard for portable water	Monitoring Points													
		Old Kampala	Nakasero	Gayaza	Kibuli	Kisugu	Mengo	Lungujja	Nansana	Nsambya	Kisaasi	Kasubi	Kiwatule	Mukono	Kagoma
pH	6.5-8.5	7.0	7.0	7.4	7.4	7.3	7.5	7.5	7.4	7.4	7.6	7.5	7.6	7.1	7.3
Electrical Conductivity ( $\mu\text{S/cm}$ )	1500	130	129	138	120	118	126	127	125	123	146	137	148	130	138
Turbidity (NTU)	5	0.37	0.33	0.53	0.41	0.45	0.35	0.42	1.38	0.34	0.53	0.38	0.46	0.58	0.56
Colour (PtCo)	15	8	7	11	9	10	7	8	9	7	10	8	10	12	12
Escherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.35	0.30	0.20	0.20	0.25	0.30	0.20	0.30	0.30	0.20	0.45	0.30	0.20