

**Report date:** 12th October 2015

**Table:** Average water quality for Kampala during the period of 5<sup>th</sup> - 9<sup>th</sup> October 2015

Parameter	Standard for portable water	Monitoring Points													
		City Centre	Kololo	Namugooona	Namuwongo	Muyenga	Rubaga	Lugala	Masanafu	Munyonyo	Lugogo	Luzira	Kirinya	Kabalagala	Wakiso
	<b>6.5-8.5</b>	7.3	7.2	7.4	7.1	7.3	7.4	7.2	7.3	7.4	7.3	7.2	7.4	7.3	6.6
Electrical Conductivity ( $\mu\text{s/cm}$ )	<b>1500</b>	136	136	133	135	134	135	136	134	134	136	133	140	134	155
Turbidity (NTU)	<b>5</b>	0.62	0.57	0.93	0.74	0.34	0.63	0.78	0.64	0.5	0.49	0.55	0.62	0.53	0
Colour (PtCo)	<b>15</b>	7	7	11	10	5	8	11	9	6	7	8	10	8	2
Esherichia coliform (cfu/100 mL)	<b>0</b>	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	<b>0</b>	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	<b>0.20 – 0.50</b>	0.30	0.30	0.20	0.25	0.45	0.20	0.25	0.25	0.45	0.30	0.35	0.20	0.40	0.20