

Report date: 05th October 2015

Table: Average water quality for Kampala during the period of 28th Sept. - 4th October 2015

Parameter						Monitoring points									
	National Standard For portable water	Matuga	Mulago	Kawempe	Mutungo	Kireka	Buloba	Bulenga	Kololo	Naguru	Wandegeya	Kamwokya	Kirinya	Rubaga	Luzira
pH	6.6-8.5	7.3	7.4	7.3	7.3	7.4	7.3	7.4	7.4	7.3	7.3	7.4	7.3	7.3	7.3
Electrical Conductivity (µs/cm)	≤1500	134	134	133	137	137	134	138	134	130	130	129	140	132	133
Turbidity (NTU)	≤5.00	0.59	0.45	0.78	0.51	0.68	0.88	0.75	0.58	0.81	0.68	0.72	0.65	0.79	0.54
Colour (PtCo)	≤15	6	3	8	5	6	9	8	5	9	7	8	6	9	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.40	0.35	0.40	0.30	0.25	0.30	0.35	0.30	0.35	0.30	0.35	0.30	0.30