

Report date: 26th October 2015

Table: Average water quality for Kampala during the period of 19th - 25th October 2015

Parameter						Monitoring points									
	National Standard For portable water	Lubowa	Munyonyo	Namasuba	Wandegeya	Makerere	Seeta	Nakasero	Namanve	Mukono	Kololo	Namilyango	Kisenyi	Banda	Luzira
pH	6.6-8.5	7.4	7.4	7.5	7.4	7.4	7.5	7.5	7.1	7.3	7.5	7.5	7.5	7.3	7.5
Electrical Conductivity (µs/cm)	≤1500	146	142	147	140	134	139	142	137	137	140	138	141	145	143
Turbidity (NTU)	≤5.00	0.89	0.48	0.64	0.78	0.68	0.81	0.72	0.84	0.78	0.76	0.87	0.75	0.89	0.72
Colour (PtCo)	≤15	7	5	9	8	7	10	5	8	5	8	10	11	12	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.35	0.25	0.30	0.25	0.25	0.35	0.30	0.35	0.30	0.25	0.35	0.25	0.30