

Report date: 28st September 2015

Table: Average water quality for Kampala during the period of 21st - 27th September 2015

Parameter						Monitoring points									
	National Standard For portable water	Namanve	Nakawa	Mukono	Seeta	Ninda	Kyebando	Matuga	Katwe	Makerere	Kyambogo	Kamwokya	Muyenga	Rubaga	Kyengera
pH	6.6-8.5	7.3	7.4	7.3	7.3	7.4	7.3	7.2	7.3	7.3	7.3	7.4	7.4	7.3	7.4
Electrical Conductivity (µs/cm)	≤1500	134	133	132	135	135	135	133	134	134	134	135	133	136	135
Turbidity (NTU)	≤5.00	0.72	0.68	0.72	0.66	0.78	0.66	0.58	0.61	0.69	0.71	0.57	0.57	0.65	0.69
Colour (PtCo)	≤15	8	7	8	6	8	6	4	5	6	7	5	4	6	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.2-0.5	0.30	0.35	0.25	0.30	0.30	0.25	0.30	0.25	0.30	0.30	0.35	0.45	0.30	0.25