

Report date: 22nd June 2015

Table: Average water quality for Kampala during the period of 15th - 19th June 2015

Parameter	National Standard for portable water	Monitoring Points													
		Kisenyi	Kyengera	Bwaise	Mengo	Lubowa	Bunamwaya	Naguru	Naalya	Mbuya	Munyonyo	Mukono	Namasuba	Seguku	Wakiso
pH	6.5-8.5	7.0	7.2	7.1	7.0	7.2	7.0	7.0	7.1	7.1	7.0	7.1	7.0	7.1	7.0
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	1500	140	139	137	139	139	142	139	142	138	137	141	139	140	153
Turbidity (NTU)	5	0.49	0.45	0.47	0.31	0.50	0.49	0.45	0.52	0.47	0.00	0.61	0.4	0.46	0
Colour (PtCo)	15	10	9	8	6	7	8	10	10	8	1	11	6	6	0
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.20	0.20	0.30	0.30	0.30	0.25	0.30	0.20	0.30	0.35	0.25	0.45	0.40	0.40