

KAMULI AREA**Report date:** 16th November -2015**Table:** water quality for selected points in Kamuli during the week of 12th November 2015

Parameter	Units	Raw water	Treated Water	Monitoring points				National Standard For potable water quality (Water in Supply)
				Water in Supply				
				Katalo PSp	Electoral commission	Bulngaire Rd side tap	Denning psp	
pH	...	7.3	7.7	6.6	6.7	6.9	6.8	6.5 – 8.5
Turbidity	NTU	183	3.1	1.05	1.00	0.81	1.18	≤5.00
Colour	PTU	13	26	0	0	0	0	≤15
Free chlorine	mg/l	N/A	6.68	0.63	0.25	0.31	0.22	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	35	0	0	0	0	0	0

NA: Not applicable