

**KAMULI AREA****Report date:** 25<sup>th</sup> November -2015**Table:** water quality for selected points in Kamuli during the week of 19<sup>th</sup> November 2015

	Monitoring points							National Standard For potable water quality (Water in Supply)
Parameter	Units	Raw water	Treated Water	Water in Supply				
				Katalo PSP	Electoral commissi on	Bulngaire Rd side tap	Denning psp	
Code		N066	N067	N068	N069	N070	N071	
pH	...	7.75	7.78	6.76	6.78	6.70	6.70	6.5 – 8.5
Turbidity	NTU	31.8	2.1	1.09	1.44	0.91	1.12	≤5.00
Colour	PTU	673	15	0	0	0	0	≤15
Free chlorine	mg/l	N/A	6.78	0.47	0.45	0.31	0.30	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	54	0	0	0	0	0	0

N/A: Not applicable