



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

KAMWENGU AREA

Report date: 12th July 2016

Table: Water quality for Selected zones in **KAMWENGU AREA** during the week ending 7th July 2016

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kaburisoke Reservoir	Voice Of Kamwenge	Rwenjaza	
Codes		-	-	-	-	-	
pH	N/R	N/R	N/R	N/R	N/R	5.5 – 8.5
Turbidity	NTU	21.69	0.99	1.07	2.27	3.14	≤5.00
Colour	PtCo.	343	1.71	4	8	9	≤15
Iron:Total	Mg/l	2.410	0.210	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	-	0.17	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.57	0.32	0.27	0.15	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	-	0	0	0	0	0