

KAMWENGES AREA

Report date: 30th November -2015

Table: Water quality for Selected points in **KAMWENGES** during the week of 26th November 2015

Parameter				Monitoring points				National Standard For potable water quality
	Unit	Raw water	Final water		Water in Supply			
				Kamwenge Reservoirs	Kamwenge Central Town	Taxi Park	Kabuga Rd	
Codes		N047	N048	N049	N050	N051	N052	
pH	NA	N/R	N/R	N/R	N/R	N/R	N/R	5.5 – 8.5
Turbidity	NTU	21.00	0.00	1.00	5.00	5.00	2.00	≤5.00
Colour	PtCo.	238	0	2	4	8	8	≤15
Iron	Mg/l	1.54	0.20	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.25	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.50	0.22	0.20	0.10	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	N/R	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required