

KAMWENGGE AREA**Report date:** 16th November-2015**Table:** Water quality for Selected zones in Kamwenge during the week of 12th November 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Kamwenge Reservoirs	Karambi	Katibani	Kabuga Road	
Codes		N035	N036	N037	N038	N039	N040	
pH	N/R	N/R	N/R	N/R	N/R	N/R	5.5 – 8.5
Turbidity	NTU	18.71	0.00	1.00	2.00	2.00	3.00	≤5.00
Colour	PtCo.	275	0	1	2	1	2	≤15
Iron	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.25	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.55	0.25	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	N/R	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required