

KAMWENGE AREA**Report date:** 20th October -2015**Table:** Water quality for Selected points in Kamwenge during the week starting 12th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kamwe nge Reserv oirs	Mpang a	Kamweng e Town Center	Kabuga Road	St. Lawrenc e S.S.	
Codes		N015	N016	N017	N018	N019	N020	N021	
pH	N/R	N/R	N/R	N/R	N/R	N/R	N/R	5.5 – 8.5
Turbidity	NTU	32.70	0.57	2.00	4.00	1.00	1.00	1.00	≤5.00
Colour	PtCo.	308	1	0	0	0	0	0	≤15
Iron	Mg/l	0.883	0.051	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.17	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.58	0.22	0.10	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	N/R	0	0	0	0	0	0	0

NR: Not Required