

KAMWENGES AREA**Report date:** 24th December -2015**Table:** Water quality for Selected zones in Kamwenge during the week starting 17th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kamw enge Reserv oirs	Karamb i	Kanye garami	Kamwe nge Central Town	Rwenja za	
CODE		N2090	N2095	N2100	N2102	N2108	N2098	N2099	
pH	7.1	7.0	6.4	6.5	6.5	6.8	6.4	5.5 – 8.5
Turbidity	NTU	16	0	0	0	0	0	0	≤5.00
Colour	PtCo.	305	0	0	0	0	0	0	≤15
Iron	Mg/L	0.59	0	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/L	NA	0.07	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.87	0.25	0.18	0.20	0.28	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	105	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required