

**KASESE AREA****Report date:** 13<sup>th</sup> January-2016**Table:** Water quality for Selected zones in Kasese during the week of 7<sup>th</sup> January-2016.

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Kasese Reservoir	Water in Supply			
					Kasese Central Town	Police Barracks	Salute	
CODE		N061	N062	N063	N064	N065	N067	
pH	....	7.6	6.7	6.3	6.6	6.6	6.5	5.5 – 8.5
Turbidity	NTU	11.90	0.71	1.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	122	5	7	0	0	4	≤15
Iron	Mg/L	0.300	0.020	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/L	N/R	0.15	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/R	0.88	0.69	0.42	0.37	0.28	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	23	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required