



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

KASESE AREA

Report date: 3rd November, 2016

Table: Water quality for Selected zones in **Kasese** during the week of 27th October, 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Reservoir	Kasese Town Center	Shauriyako	Taxi Park	
Codes		N1339	N1340	N1341	N1342	N1342	N1344	
pH	...	6.9	6.7	6.7	6.6	6.6	6.7	5.5 – 8.5
Turbidity	NTU	18.00	2.00	1.00	3.00	3.00	3.00	≤5.00
Iron	Mg/l	0.310	0.060	N/R	N/R	N/R	N/R	≤0.300
Free chlorine	mg/L	NA	1.50	0.60	0.20	0.30	0.30	0.20 – 0.50
Faecal –Coliform	CFU/ 100 mL	150	0	0	0	0	0	0