



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

KASESE

Report date: 12th Oct 2016

Table: Water quality for Selected zones in **KASESE AREA** during the week ending 6th Oct2016

Parameter					Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kasese Reservoir	Parents Primary School	Tema ngalo	Acholi Quarte rs	Katad ooba	
Codes		-	-	-	-	-	-	-	
pH	6.9	6.8	6.0	5.9	6.1	6.3	6.0	5.5 – 8.5
Turbidity	NTU	33.60	0.43	0.00	0.20	0.00	0.20	0.00	≤5.00
Colour	PtCo.	327	3	0	11	4	14	0	≤15
Free chlorine	mg/L	NA	0.96	0.60	0.20	0.30	0.10	0.20	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	-	0	0	0	0	0	0	0