



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**KASESE AREA**

**Report date:** 10<sup>th</sup> June 2016

**Table:** Water quality for Selected zones in **KASESE** during the week of 2<sup>nd</sup> June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Reservoirs	Railways	Kasese Town Center	Base Camp	
Codes		N100	N101	N102	N103	N104	N105	
pH	....	6.7	6.7	6.8	6.7	6.7	6.7	5.5 – 8.5
Turbidity	NTU	30.00	1.90	2.00	1.00	1.00	2.00	≤5.00
Colour	PtCo.	257	11	13	11	9	10	≤15
Iron	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.15	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.85	0.60	0.30	0.20	0.50	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	10	0	0	0	0	0	0