

**KASESE AREA**Report date: 5<sup>th</sup> July -2015Table: Water quality for different zones in Kabale during the week of 1<sup>st</sup> July 2015

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kasese Reservoir	Kasese Central Town	Nyamwamba Zone	
pH	....	6.55	6.10	5.89	5.80	5.78	5.5 – 8.5
Turbidity	NTU	9.00	0.20	1.00	0.00	0.00	≤5.00
Colour	PtCo.	133	5.8	0	2	2	≤15
Free chlorine	mg/L	NA	0.75	0.50	0.27	0.31	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	11	0	0	0	0	0