

KASESE AREA**Report date:** 30th November -2015**Table:** Water quality for Selected points in **KASESE** during the week of **26th** November 2015

Parameter				Monitoring points					National Standard For potable water quality
	Unit	Raw water	Final water	Water in Supply					
				Kasese Reserv oir	Kigoro Police	Kogere	Fort Portal Road	Umoja	
Codes		N040	N041	N042	N043	N044	N045	N046	
pH	NA	7.4	6.6	6.7	6.7	6.9	6.2	6.6	5.5 – 8.5
Turbidity	NTU	12.10	0.86	2.00	2.00	1.00	1.00	1.00	≤5.00
Colour	PtCo.	118	9	15	15	15	14	15	≤15
Iron	Mg/l	0.41	0.03	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/R	0.20	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.84	0.46	0.20	0.20	0.21	0.23	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	35	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required