

KASESE AREA**Report date:** 15th September -2015**Table:** Water quality for Selected zones in Mbarara during the week of 11th September 2015

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kasese Reservoir	Kasese Central Town	Nyamwamba Zone	
Codes		N006	N007	N008	N009	N010	
pH	7.46	6.6	6.8	6.7	6.8	5.5 – 8.5
Turbidity	NTU	15.00	0.70	2.00	2.00	2.00	≤5.00
Colour	PtCo.	157	4.6	10	15	14	≤15
Iron	Mg/l	0.250	0.140	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	NA	0.08	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	0.94	0.47	0.22	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	380	0	0	0	0	0

NA – Not applicable, NR – Not required