

KASESE AREA**Report date:** 20th October -2015**Table:** Water quality for Selected points in Kasese during the week starting 12th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kasese Res	Kasese Central Town	Kogere	Temangalo Lower	Umoja	
Codes		N033	N034	N035	N036	N037	N038	N039	
pH	7.5	6.6	6.6	6.4	7.1	6.5	7.2	5.5 – 8.5
Turbidity	NTU	14.40	0.14	0	0	0	1.00	1.00	≤5.00
Colour	PtCo.	133	2	0	7	15	15	14	≤15
Iron	Mg/l	0.390	0.020	N/R	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.09	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.89	0.67	0.21	0.20	0.28	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	50	0	0	0	0	0	0	0

NR: Not required