

KASESE AREA**Report date:** 24th December -2015**Table:** Water quality for Selected points in Kasese during the week of 17th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kasese Reserv oir	Base Camp	Nyaka sanga	Katado ba	Kamulik wizi	
Codes		N061	N062	N063	N064	N065	N066	N067	
pH	7.7	6.8	6.9	6.9	6.9	6.9	6.9	5.5 – 8.5
Turbidity	NTU	11.10	1.00	0.00	0.00	2.00	1.00	0.00	≤5.00
Colour	PtCo.	107	7	0	0	13	8	4	≤15
Iron	Mg/L	0.40	0.02	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/R	0.10	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/R	0.91	0.69	0.63	0.18	0.42	0.39	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	N/R	0	0	0	0	0	0	0