

KASESE AREAReport date: 24th July -2015Table: Water quality for selected zones in kasese during the week of 20th July 2015

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kasese Reservoir	Kasese Central Town	Nyamwamba Zone	
pH	7.4	6.6	6.8	6.8	6.9	5.5 – 8.5
Turbidity	NTU	11.3	0.70	2.00	0.00	1.00	≤5.00
Colour	PtCo.	104	3.3	10	0	8	≤15
Free chlorine	mg/L	N/A	0.85	0.56	0.21	0.26	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	17	0	0	0	0	0