

## KASESE AREA

**Report date:** 13<sup>th</sup> June -2015

**Table:** Water quality for Selected zones s in Kasese during the week of 6<sup>th</sup> July 2015

Parameter	Monitoring points					National Standard  For potable water quality  (Water in Supply)
	Unit	Raw water	Final water	Water in Supply in Mbarara Town		
				Kasese Central Town	Nyamwamba zone	
pH	...	6.0	6.8	6.2	6.3	5.5 – 8.5
Turbidity	NTU	8.0	0	1	1	≤5
Colour	PtCo.	97	4	3	3	≤15
Free chlorine	mg/L	NA	0.6	0.2	0.2	0.2 – 0.5
E-Coli	CFU/100 mL	0	0	0	0	0
Faecal - Coliform	CFU/ 100 mL	5	0	0	0	0